



Safety certificate K6528/11

Issued 2017-07-01

Replaces K6528/10

Page 1 of 3

Combi food steamers

STATEMENT BY KIWA

With this product certificate, issued in accordance with the Kiwa Regulations for Product Certification, Kiwa declares that legitimate confidence exists that the products supplied by

RATIONAL AG

comply with the technical specifications as laid down in this safety certificate and are marked with the Kiwa®-mark as specified in this safety certificate are, on delivery, relied upon to comply with Kiwa evaluation guideline

BRL-K14011/01 “Aspects of technical water supply protection for appliances with a contamination risk”

wherein the requirements of

EN 1717: 2000 “Protection against pollution of potable water in water installations and general requirements of devices to prevent pollution by backflow”.

are applied for analyzing the risk of contamination by backflow and for selecting the appropriate backflow prevention unit(s).

Luc Leroy
Kiwa

Publication of this certificate is allowed.

Advice: consult www.kiwa.nl in order to ensure that this certificate is still valid.

CERTIFICATE

301170001

Kiwa Nederland B.V.

Sir Winston Churchillaan 273
Postbus 70
2280 AB RIJSWIJK
The Netherlands
Tel. +31 88 998 44 00
Fax +31 88 998 44 20
info@kiwa.nl
www.kiwa.nl

Supplier

RATIONAL AG
IGLINGER STRASSE 62
86899 LANDSBERG AM LECH
Germany
Tel. +49-8191 327 0
Fax +49 8191 21735
www.rational-ag.com
info@rational-online.com

Combi food steamers

Product specification

The following types are covered by this certificate

Model	Backflow prevention unit	Year of manufacture
Rational CM 61, 62, 101 and 102	AB ^{NB1} & EB ^{NB3}	2004 – 2011
Rational CM 201 and 202	AB ^{NB1} & EB ^{NB3}	2004 – 2011
Rational CM 61G, 62G, 101G, 102G, 201G and 202G	AB ^{NB1} & EB ^{NB3}	2004 – 2011
Rational SCC 61, 62, 101 and 102	AB ^{NB1} & EB ^{NB3}	2004 – 2008
Rational SCC 61G, 62G, 101G, 102G, 201G and 202G	AB ^{NB1} & EB ^{NB3}	2004 – 2008
Rational SCC 61, 62, 101 and 102, with Care system	AB ^{NB1} & AF ^{NB2} & EB ^{NB3}	2008 – 2011
Rational SCC 201 and 202, with Care system	AB ^{NB1} & AF ^{NB2} & EB ^{NB3}	2008 – 2011
Rational SCC 61G, 62G, 101G, 102G, 201G and 202G with Care system	AB ^{NB1} & AF ^{NB2} & EB ^{NB3}	2008 – 2011
Rational CMP 61, 62, 101, 102, 201 and 202 E +G	AB ^{NB1} & AA ^{NB4} & EB ^{NB3}	2011 -
Rational CMP 61, 101 and 102 V	AB ^{NB1} & AA ^{NB4} & EB ^{NB3}	2017 -
Rational SCC WE 61, 62, 101, 102, 201 and 202 E+G with Care system	AB ^{NB1} & AA ^{NB4} & AF ^{NB2} & EB ^{NB3}	2011 -
Rational SCC WE 61, 101 and 102 V with Care System	AB ^{NB1} & AA ^{NB4} & AF ^{NB2} & EB ^{NB3}	2017 -
Rational CM 61 and 101	AB ^{NB1} & AA ^{NB4} & EB ^{NB3}	2017 -
Rational SCC XS 6 2/3E	AB ^{NB1, NB2, NB5} & AA ^{NB4} & EB ^{NB3}	2016 -
Rational SCC XS UV, SCC XS UV+, UltraVent XS Integration	AB ^{NB1, NB2, NB5} & AA ^{NB4} & EB ^{NB3}	2017 -
Rational CMP XS 6 2/3E	AB ^{NB1} & AA ^{NB4} & CA ^{NB3}	2017 -
Rational CMP XS UV, CMP XS UV+, UltraVent XS Integration	AB ^{NB1} & AA ^{NB4} & CA ^{NB3}	2017 -

NB1 :Condenser, Control box

NB2 :Care system

NB3 :Drinking water connection point

NB4 :Hand shower

NB5 :Steam generator

Application and use

This certificate applies to quantity-produced "appliances with a contamination risk" intended for connection to drinking water installations. These appliances must be equipped with a backflow prevention unit at the feed in conformance with NEN 1006 that is appropriate for covering the risk of backflow of contaminating substances. The backflow prevention unit shall prevent that water upstream from the protection point will be contamination as a result of backflow from the appliances with a contamination risk and/or downstream connected applications or installation.

Combi food steamers

Marking

The products shall be marked with one of the following sticker



Location of the mark:

on the outside near the water inlet connection point.

Further compulsory specifications:

- suppliers mark or logo;
- type nomination.

Method of marking:

- indelible;
- visible after mounting.

RECOMMENDATIONS FOR CUSTOMERS

Check at the time of delivery whether:

- the supplier has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport etc.

If you should reject a product on the basis of the above, please contact:

- RATIONAL AG
- and, if necessary,
- Kiwa Nederland B.V.

This certificate is only valid for the technical water supply part of the product of installation. Kiwa declares herewith that the construction of this technical water supply has been conducted in such way, contamination of the drinking water installation will be prevented. Herewith Kiwa gives no statement with respect to the function or the efficiency of the under these declaration supplied products.

Consult the supplier's processing guidelines for the proper storage and transport methods.